

SAMPLE DENIAL LETTER:

A plan approval document will be provided, and it may include items at the bottom that you still need to provide to State Fire Marshal.

**State Fire Marshal
800 SW Jackson
Suite 104
Topeka, KS 66612-1216
PLAN REVIEW DENIED**

Fri Nov 4, 2022

KIDS Occupancy File Number:

We have completed a review of the design submittal received on
The design submittal fails to comply with the fire and life safety Fire Prevention Code. Please refer to the violations listed below.
Please correct the violations listed below and resubmit your design to our office within 90 days from the date of this letter. If there is no correspondence within the allotted 90 days, your original design submittal will be recycled.

KANSAS REGULATION AND FINDINGS

06-PLN-11 DESIGNER SEAL

KAR 22-1.7

The designer's seal (RA or PE) is illustrated.

Findings Include:

- ALL PAGES OF THE CODE FOOTPRINT ARE MISSING THE DESIGNERS SEAL/STAMP

06-PLN-12 ROOM IDENTIFICATION

KAR 22-1.7

Each room and space is identified by name or number.

Findings Include:

- THERE ARE NO ROOM NUMBERS OR ROOM IDENTIFIERS LISTED ON THE CODE FOOTPRINT

06-PLN-39 FACP

KAR 22-1.7 2006 IBC & IFC Section 907

The location of the fire alarm control panel and any remote annunciator panel is illustrated.

Findings Include:

- LOCATION OF FIRE ALARM CONTROL PANEL NOT IDENTIFIED
-