

## **Emergency lighting:**

Emergency lighting is installed to give occupants enough light to reach an exit during an evacuation. Emergencies that require evacuation may also cause the lights to go out. This is no time to be in the dark.

The codes allow emergency lighting to be provided in different ways, but the most common method is the use of battery powered units. Battery powered emergency lights are relatively inexpensive, reliable, readily available off-the-shelf, and easy to install. Units that are tested, listed, and labeled by a recognized testing lab such as Underwriter's Laboratories help provide assurance of performance and reliability.

## **Installation Pointers:**

Emergency lighting is required to illuminate routes leading to a required emergency exit. These routes include stairs, aisles, corridors, ramps, escalators, and passageways. An average of 1 footcandle at the floor is the minimum required level of illumination but common-sense installation usually exceeds this level. Actual measurement of light levels is rarely done. It is easier and usually cheaper to simply install more emergency lighting units in marginal areas. The best way for you to check the level of light is to simply try the emergency lighting on a dark night and see if the exit paths are adequately lit.

The units should be installed to provide adequate coverage over the most area. A two-light unit can be installed halfway down the length of a corridor and the lights pointed in each direction to cover the entire corridor. Don't aim the lights where they will shine directly in someone's eyes. It is better to light the path at the floor and illuminate the exit. Be certain the lights are connected to the lighting circuit so they will work when the lights fail, even if other circuits remain energized.

## **Where Emergency Lighting is Required:**

Emergency lighting is required to be installed in all buildings required to have two or more exits. Testing and Maintenance.

Emergency lighting systems and units must be periodically tested to determine operability in an emergency. Testing will also indicate which units need maintenance or replacement. The Fire Codes require that the emergency power system must provide power for a duration of not less than 90 minutes. The lights must be tested to verify operation for the entire 90 minutes. Written records must be kept of the testing and be available for inspection.

## **Additional Federal Healthcare Requirements:**

Emergency lighting units must consist of 2 bulbs as the failure of any single bulb must not result in illumination levels less than the minimum required. Emergency lights are not allowed to be tied into a light switch as that switch may interrupt the restoration of lights. All emergency lights must be tested for 30 seconds monthly and 90 minutes annually.

