Emergency Light Testing Log:

Although documentation must be kept, this exact form does not need to be used. Facilities are welcome to use this form as a guideline to develop their own format, or to use the form as shown for recordkeeping.

Requirements:	Monthly –	30 Sec
	Annual –	90 Min

Note: You must conduct a 30 second functional test every month regardless of if you conduct the 90 minutes annual test.

Unit location and type	Jan:	Feb:	Mar:	Apr:	May:	Jun:	Jul:	Aug:	Sep:	Oct:	Nov:	Dec:	Annual:	Comments

1.) Provide a date tested for each month
2.) Initial each unit tested
3.) Comments should include information regarding failure & replacement