

Openings:

Doors shall be labeled, self- or automatic closing, and shall be provided with an active latch that will secure the door when it is closed.

Penetrations:

Prohibited, except for exit doors and any equipment or ductwork necessary for independent pressurization, sprinklering, etc.

Directional signs:

Signs must be provided to direct occupants to the level of exit discharge. Signs shall not direct occupants to re-enter the building.

Floor numbers:

For stairs connecting more than 3 stories, a sign shall be provided on each floor landing designating the floor level, the terminus of the top and bottom of stairs, the identification of the stair, and the availability of roof access for the fire department.