

Office of the State Fire Marshal

Fire Extinguisher that is NOT APPROVED

AKE Safety Equipment has a product on the market, by the name of, STOP-FYRE. A portable fire extinguisher that uses a blend of clean agent liquefied fire suppression gases. It is being sold in Kansas but is not approved by our office.



Code states:

NFPA 10, 1998 Edition

1-4.3 require fire extinguishers to have a UL listing or listing from another recognized testing laboratory indicating the product has been tested and meet or exceed the performance standards for fire extinguishers.

This product does not have any of those listings.

Vendors in Kansas could be selling them under McClure Farms Partnership. Should your facility have one of these extinguishers you will receive a citation.



**Office of the State Fire Marshal
800 SW Jackson Suite, 104
Topeka KS 66612
785-296-3401
www.ksfm.ks.gov**